



TNB RESEARCH

Innovate With The End In Mind

“TECHNICAL FEASIBILITY OF CO-FIRING AMMONIA AND SUB-BITUMINOUS COALS IN A PILOT-SCALED COMBUSTOR”

by:

Dr. Mohd Hariffin Boosroh

Managing Director, TNB Research Sdn Bhd.


2nd International Conference on Fuel Ammonia

28^h September 2022



We believe that our sustainability pathway towards 2050 will open new growth opportunities whilst remaining true to our core role

Target of 8.3GW RE by 2025
Commitment of 35% reduction of our emission intensity by 2035
Aspire to achieve Net Zero emissions by 2050



Our journey for the next 5 years is still guided by Reimagining TNB – the medium term goals to 2025 still remain



Our case study:

Demonstration of the technical feasibility of co-firing ammonia at TNB Research combustion test facility involved three parties



IHI




-
- To supply Ammonia for co-firing assessment
 - Provide technical advisory on feasibility of Ammonia co-firing
 - Execute pilot scale testing for co-firing assessment

Key aims are

- (i) To determine what are the conditions required for the reduction of emission release in ammonia co-firing
- (ii) To obtain the flame temperatures for insights on in furnace real time monitoring
- (iii) To ascertain unburnt carbon reduction in ammonia co-firing.

TNBR Combustion Test Rig for Ammonia co-firing testing programme



A total set of 6 testing conditions were established whereby each conditions was conducted daily:

- Melawan Coal single firing
- Melawan – ammonia co-firing
- SM Coal single firing
- SM Coal – ammonia co-firing
- MHU Coal single firing
- MHU Coal – ammonia co-firing

- To obtain swirl air flow, **swirl vane** was installed into the combustion air flow; The swirl intensity influence the NOx emissions; a pulverised **coal flame is established**
- LPG is used for support fuel to maintain the furnace temperature
- In all ammonia co-firing conditions, **leakage ammonia was checked using a detector tube and was not detected in any case (0 ppm).**


Equipment parameter	Capacity	Remarks
Ammonia flowrate	0 - 10 kg/hr	Depends on testing condition
Primary air flowrate	9 Nm ³ /hr	Fixed throughout this programme
Coal flowrate	0 - 40 kg/hr	Depends on testing condition
Secondary air flowrate	0 - 150 Nm ³ /hr	Depends on coal properties
Staging air flowrate	0 – 45 Nm ³ /hr	Typically 0%, 30%, 40%
LPG flowrate	2 kg/hr	Fixed throughout this programme



Burner part



Section 1



Section 2, 3, 4



Conclusions

- Assessment on co-firing impact was successfully carried out whereby the flame temperature as in furnace real time monitoring for both single and ammonia co-firing conditions for all the tested coals do not vary significantly.
- Reduction of CO₂ and SO₂ emissions were achieved when firing the coal: ammonia 40:60 ammonia, while the increasing of NO_x was found to be under controlled through staged combustion application.
- No ammonia slip was found at the furnace exit throughout the testing programme.
- However, future research is needed to determine the optimal method of NO_x reduction.



TNB RESEARCH

**Thank
You**



Acknowledgment to TNB, PETRONAS, and IHI for their financial and technical support

Dr. Mohd Hariffin Boosroh

TNB Research

hariffinb@tnb.com.my

www.tnbr.com.my

